# ABC DRY POWDER MAP-90% STORED PRESSURE 1 KG SS BODY FIRE EXTINGUISHER



Applicable Class of fire - A, B, C and electrically started fires.

**Brief description:** These extinguishers come with nominal charge of 1 kg dry powder, Constructed of SS Sheet of 1.5 mm thickness and brass forged discharge Valve with MS lever.

| | | | |
|---|---|---|---|
| **1** | **GENERAL DATA** | | |
| | Manufacturer | : | Intime Fire Appliances Pvt. Ltd. |
| | Trade Mark | : | "**INTIME**" |
| | BIS standard code | : | IS 15683:2018 |
| | Type | : | Portable Stored Pressure |
| **2** | MATERIAL OF CONSTRUCTION | | |
| | Extinguishing medium | : | Mono Ammonium Phosphate **(MAP-90%)** dry powder (IS 4308:2019) |
| | Body | : | Stainless steel sheet of 1.5 mm thickness |
| | Neck Ring | : | SS - M30 x 1.5 Female threaded |
| | Valve | : | Brass - M30 x 1.5 Male threaded |
| | Siphon tube | : | Aluminium / PVC |
| | Pressure gauge / indicator | : | As per IS 15683:2018 |
| | Discharge nozzle | : | Brass / PVC |
| | Wall mounting bracket | : | MS Powder coated /Chrome Plated |
| **3** | **PERFORMANCE DATA** | | |
| | Fire rating | : | 1A : 21B |
| | Performance requirements | : | **Min. Effective discharge time** : 8 Sec. ( Actual : 13 Sec. Approx.) |
| | | : | **Min. Bulk range of discharge** : 2 Mtr. ( Actual : 3.5 Mtr. Approx.) |
| | | : | **Min. Percentage of discharge** : 85% ( Actual : 94% Approx.) |
| | Temperature Range | : | -20° to +60° C |
| | Service pressure | : | 15 bar |
| | Max. service pressure | : | 18 bar |
| **4** | **ROUTINE TESTS** | | |
| | Hydro Pressure Test (Pt) | : | 35 bar (3.5 MPa) Hold for 2.5 min. |
| | Min. Burst pressure (Pb) for body | : | 55 bar (5.5 MPa) Hold for 1 min. |
| | Leakage test | : | Inverted glass jar / Soap solution |
| | Partial discharge | : | The second pressure or weight shall not be less than 75% of the first after interruption of the Discharge |
| **5** | **TYPE TESTS** | : | As per IS 15683:2018 |
| **6** | **DIMENSIONS** | : | **Diameter** : 80 ± 10 mm |
| | | : | **Height** : 300 ± 10mm Approx. |
| | Full weight of extinguisher | : | 2.2 kg (Approx.) |
| **7** | **MISCELLEANEOUS** | | |
| | Inspection & testing | : | As per approved QAP |
| | Finish | : | PO Red as per IS : 5 (Shade 538) |
| | Marking | : | As per IS 15683:2018 |
| | Approvals | : | PED |
| | Maintenance, care and refilling | : | As per IS 2190 |
| **8** | **IN BOX ACCESSORIES** | : | Wall mounting bracket |
| **9** | **PACKING** | : | Corrugated boxes |

MARKING: AS PER IS 15683:2018


APPROVAL : PED MARKED

DESIGN DATA

| SR. NO | PARTICULARS | DESCRIPTION |
|---|---|---|
| 01 | CAPACITY | 1 KG ± 2% |
| 02 | TEMPERATURE RANGE | -20°C TO +60°C |
| 03 | SERVICE PRESSURE | 15 bar |
| 04 | MAX. SERVICE PRESSURE | 18 bar |
| 05 | PRESSURE TEST (PT) | 35 bar HOLD FOR 2.5 min. |
| 06 | MIN. BURST PRESSURE TEST (PB) | 55 bar HOLD FOR 1 min. |

PERFORMANCE PARAMETERS

| SR. NO | PARTICULARS | DESCRIPTION |
|---|---|---|
| 01 | EFFECTIVE DISCHARGE TIME | MIN. 8 SEC. (Actual: 13 sec. aprx.) |
| 02 | BULK RANGE OF DISCHARGE | MIN. 2 METER (Actual: 3.5 meter aprx.) |
| 03 | PERCENTAGE OF DISCHARGE | NOT LESS THAN 85% (Actual: 94% aprx.) |
| 04 | FIRE RATING | 1A-21B |







**300** mm ± 10 mm Approx.

Ø80 ± 10 mm
(Approx)

| SR. NO | DESCRIPTION | MATERIAL | QTY. |
|---|---|---|---|
| 13 | EXTINGUISHING MEDIUM | MAP 90% POWDER CONFIRMS TO IS 4308:2019 | 01 |
| 12 | WALL MOUNTING BRACKET | MS POWDER COATED / CHROME PLATED | 01 |
| 11 | NOZZLE | PVC | 01 |
| 10 | SEAL | PP PLASTIC | 01 |
| 09 | SIPHON TUBE | ALUMINUM / PVC | 01 |
| 08 | "O" RING | NITRILE RUBBER | 01 |
| 07 | SAFETY PIN HOLDER | RUBBER / SOFT PVC | 01 |
| 06 | SAFETY PIN | MS CHROME PLATED | 01 |
| 05 | LEAVER LOCK | PP PLASTIC | 01 |
| 04 | PRESSURE GAUGE / INDICATOR | AS PER IS 15683:2018 | 01 |
| 03 | VALVE | BRASS - M30 X 1.5 MALE THREADED | 01 |
| 02 | NECK RING | STAINLESS STEEL - M30 X 1.5 FEMALE THREADED | 01 |
| 01 | BODY | STAINLESS STEEL SHEET OF 1 .5 MM THICKNESS | 01 |

| SYMBOL | REVISION DECRIPTION | DATE | BY |
|---|---|---|---|
| | | | |
| | | | |
| | | | |

| | DATE | NAME |
|---|---|---|
| DRAWN | 22.12.22 | VIJAY |
| CHECK | 22.12.22 | SHEKHAR |
| APP | 22.12.22 | AM |

TITLE :
ABC DRY POWDER MAP-90% (STORED PRESSURE)
SS BODY 1 KG FIRE EXTINGUISHER

GAD NO. : INTIME-ABC-1-90%-SP-SS


INTIME FIRE APPLIANCES PVT LTD
R.O. : 21/A, Ghanshyam Industrial Estate, Veera Desai Road, Andheri (W), Mumbai - 400053. Telephone : +91 22 2673 1826/ 2673 1852/ 4601 4392
WORKS: D-24/6, TTC Industrial Area, MIDC, Turbhe, Navi Mumbai - 400705.
Telefax: 27634433 / 64512311 / 64623611.


SCALE : NTS | SHEET : 1 OF 1