ABC DRY POWDER MAP-90% UL LISTED STORED PRESSURE 4 KG SS BODY FIRE EXTINGUSHER



Applicable Class of fire - A, B, C and electrically started fires.

Brief description: These extinguishers come with nominal charge of 4 kg dry powder,
Constructed of SS Sheet made of 1.5 mm thickness and brass forged discharge Valve with MS Lever.

1	**GENERAL DATA**		
	Manufacturer	:	Intime Fire Appliances Pvt. Ltd.
	Trade Mark	:	"**INTIME**"
	BIS standard code	:	IS 15683:2018
	Type	:	Portable Stored Pressure
2	**MATERIAL OF CONSTRUCTION**		
	Extinguishing medium	:	Mono Ammonium Phosphate **(MAP-90%) UL Listed** dry powder (IS 4308:2019)
	Body	:	Stainless steel sheet of 1.5 mm thickness
	Neck Ring	:	SS - M30x1.5 Female threaded
	Valve	:	Brass - M30x1.5 Male threaded
	Siphon tube	:	Aluminum / PVC
	Pressure gauge / indicator	:	As per IS 15683:2018
	Discharge hose with nozzle	:	Rubber braided EPDM hose with PVC nozzle (Burst pressure ≥ 55 bar)
	Wall mounting bracket	:	MS Powder coated /Chrome Plated
3	**PERFORMANCE DATA**		
	Fire rating	:	3A : 89B
	Performance requirements	:	**Min. Effective discharge time** : 8 Sec. (Actual : 19 Sec. Approx.)
		:	**Min. Bulk range of discharge** : 2 Mtr. (Actual : 3.5 Mtr. Approx.)
		:	**Min. Percentage of discharge** : 85% (Actual : 94% Approx.)
	Temperature Range	:	-30° to +60° C
	Service pressure	:	15 bar
	Max. service pressure	:	18 bar
4	**ROUTINE TESTS**		
	Hydro Pressure Test (Pt)	:	35 bar (3.5 MPa) Hold for 2.5 min.
	Min. Burst pressure (Pb) for body	:	55 bar (5.5 MPa) Hold for 1 min.
	Leakage test	:	Inverted glass jar / Soap solution
	Partial discharge	:	The second pressure or weight shall not be less than 75% of the first after interruption of the Discharge
5	**TYPE TESTS**	:	As per IS 15683:2018
6	**DIMENSIONS**	:	**Diameter** : 140 ± 10 mm
		:	**Height** : 500 ± 10 mm Approx.
	Full weight of extinguisher	:	9.5kg (Approx.)
7	**MISCELLEANEOUS**		
	Inspection & testing	:	As per approved QAP
	Finish	:	PO Red as per IS : 5 (Shade 538)
	Marking	:	As per IS 15683:2018
	Approvals	:	PED
	Maintenance, care and refilling	:	As per IS 2190
8	**IN BOX ACCESSORIES**	:	Wall mounting bracket
9	**PACKING**	:	Corrugated boxes

MARKING: AS PER IS 15683:2018


APPROVAL : PED MARKED

DESIGN DATA

SR. NO	PARTICULARS	DESCRIPTION
01	CAPACITY	4 KG ± 2%
02	TEMPERATURE RANGE	-30°C TO +60°C
03	SERVICE PRESSURE	15 bar
04	MAX. SERVICE PRESSURE	18 bar
05	PRESSURE TEST (PT)	35 bar HOLD FOR 2.5 min.
06	MIN. BURST PRESSURE TEST (PB)	55 bar HOLD FOR 1 min.

PERFORMANCE PARAMETERS

SR. NO	PARTICULARS	DESCRIPTION
01	EFFECTIVE DISCHARGE TIME	MIN. 8 SEC. (Actual: 19 sec. aprx.)
02	BULK RANGE OF DISCHARGE	MIN. 2 METER (Actual: 3.5 meter aprx.)
03	PERCENTAGE OF DISCHARGE	NOT LESS THAN 85% (Actual: 94% aprx.)
04	FIRE RATING	3A:89B





500 mm ± 10 mm Approx.

Ø140 ± 10 mm
(Approx)

13	EXTINGUISHING MEDIUM	MAP 90% UL LISTED POWDER CONFIRMS TO IS 4308:2019	04
12	WALL MOUNTING BRACKET	MS POWDER COATED / CHROME PLATED	01
11	HOSE WITH NOZZLE	RUBBER BRAIDED EPDM HOSE WITH PVC NOZZLE(BURST PRESSURE >55 bar)	01
10	SEAL	PP PLASTIC	01
09	SIPHON TUBE	ALUMINUM / PVC	01
08	"O" RING	NITRILE RUBBER	01
07	SAFETY PIN HOLDER	RUBBER / SOFT PVC	01
06	SAFETY PIN	MS CHROME PLATED	01
05	LEAVER LOCK	PP PLASTIC	01
04	PRESSURE GAUGE / INDICATOR	AS PER IS 15683:2018	01
03	VALVE	BRASS - M30 X 1.5 MALE THREADED	01
02	NECK RING	STAINLESS STEEL - M30 X 1.5 FEMALE THREADED	01
01	BODY	STAINLESS STEEL SHEET OF 1 .5 MM THICKNESS	01
SR. NO	DESCRIPTION	MATERIAL	QTY.

					DATE	NAME
				DRAWN	22.12.22	VIJAY
				CHECK	22.12.22	SHEKHAR
				APP	22.12.22	AM
SYMBOL	REVISION DECRIPTION	DATE	BY			

TITLE :

ABC DRY POWDER MAP-90% UL Listed (STORED PRESSURE)
SS BODY 4 KG FIRE EXTINGUISHER

GAD NO. : INTIME-ABC-4-UL-90%-SP-SS

INTIME FIRE APPLIANCES PVT LTD
R.O. : 21/A, Ghanshyam Industrial Estate, Veera Desai Road, Andheri (W), Mumbai - 400053. Telephone : +91 22 2673 1829/ 2673 1852/ 4601 4392
WORKS: D-24/6, TTC Industrial Area, MIDC, Turbhe, Navi Mumbai - 400705.
Telefax: 27634433 / 64512311 / 64623611.

SCALE : NTS | SHEET : 1 OF 1