CLEAN AGENT (FK-5-1-12) STORED PRESSURE 4 KG MS BODY FIRE EXTINGUISHER

Applicable Class of fire - A, B, C and electrically started fires.

Brief description: These extinguishers come with nominal charge of 4 kg clean agent **(FK-5-1-12)** UL Listed gas, Constructed of MS Sheet of 1.5 mm thickness and brass forged discharge valve with MS lever.



1	**GENERAL DATA**		
	Manufacturer	:	Intime Fire Appliances Pvt. Ltd.
	Trade Mark	:	"**INTIME**"
	BIS standard code	:	IS 15683:2018
	Type	:	Portable Stored Pressure
2	**MATERIAL OF CONSTRUCTION**		
	Extinguishing medium	:	Clean agent (FK-5-1-12) UL Listed gas
	Body	:	MS sheet of 1.5 mm Thickness
	Neck Ring	:	MS Pipe - M30x1.5 Female threaded
	Valve	:	Brass - M30x1.5 Male threaded
	Siphon tube	:	PVC / Aluminum
	Discharge hose	:	Rubber braided EPDM hose with PVC nozzle (Burst pressure ≥ 55 bar)
	Pressure gauge / indicator	:	As per IS 15683:2018
	Wall mounting bracket	:	MS Powder coated / Chrome Plated
3	**PERFORMANCE DATA**		
	Fire rating	:	2A : 34B
	Performance requirements	:	**Min. Effective discharge time :** 13 Sec. (Actual : 17 Sec. Approx.)
		:	**Min. Bulk range of discharge :** 2 Mtr. (Actual : 3.5 Mtr. Approx.)
		:	**Min. Percentage of discharge :** 95% (Actual : 96% Approx.)
	Temperature Range	:	-20° to +60° C
	Service pressure	:	10 bar
	Max. service pressure	:	12 bar
4	**ROUTINE TESTS**		
	Hydro Pressure Test (Pt)	:	35 bar (3.5 MPa) Hold for 2.5 min.
	Min. Burst pressure (Pb) for body	:	55 bar (5.5 MPa) Hold for 1 min.
	Leakage test	:	Inverted glass jar / Soap solution
	Partial discharge	:	The second pressure or weight shall not be less than 75% of the first after interruption of the Discharge
5	**TYPE TESTS**	:	As per IS 15683:2018
6	**DIMENSIONS**	:	**Diameter :** 140 ± 10 mm
		:	**Height :** 500 ± 10 mm Approx.
	Thickness of sheet	:	Made up from 1.5 mm thick sheet
	Full weight of extinguisher	:	7.5kg (Approx.)
7	**ANTI-CORROSIVE TREATMENT**	:	Phosphate treatment followed by epoxy powder coating of body DFT not less than 50 Micron
8	**MISCELLEANEOUS**		
	Inspection & testing	:	As per approved QAP
	Finish	:	PO Red as per IS : 5 (Shade 538)
	Marking	:	As per IS 15683:2018
	Approvals	:	BIS / PED
	Maintenance, care and refilling	:	As per IS 2190
9	**IN BOX ACCESSORIES**	:	Wall mounting bracket
10	**PACKING**	:	Corrugated boxes

MARKING: AS PER IS 15683:2018

APPROVAL : PED MARKED


DESIGN DATA

SR. NO	PARTICULARS	DESCRIPTION
01	CAPACITY	4 KG
02	TEMPERATURE RANGE	-20°C TO +60°C
03	SERVICE PRESSURE	15 bar
04	MAX. SERVICE PRESSURE	18 bar
05	PRESSURE TEST (PT)	35 bar HOLD FOR 2.5 min.
06	MIN. BURST PRESSURE TEST (PB)	55 bar HOLD FOR 1 min.

PERFORMANCE PARAMETERS

SR. NO	PARTICULARS	DESCRIPTION
01	EFFECTIVE DISCHARGE TIME	MIN. 13 SEC. (Actual: 17 sec. aprx.)
02	BULK RANGE OF DISCHARGE	MIN. 2 METER (Actual: 3.5 meter aprx.)
03	PERCENTAGE OF DISCHARGE	NOT LESS THAN 95% (Actual: 96% aprx.)
04	FIRE RATING	2A: 34B

HARD PUNCH MARKING
INTIME YEAR PT 35 BAR CE 1128





SR. NO	DESCRIPTION	MATERIAL	QTY.
13	EXTINGUISHING MEDIUM	CLEAN AGENT (FK-5-1-12) UL LISTED GAS	04
12	WALL MOUNTING BRACKET	MS POWDER COATED / CHROME PLATED	01
11	HOSE WITH NOZZLE	RUBBER BRAIDED EPDM HOSE WITH PVC NOZZLE (BURST PRESSURE ≥ 55 BAR)	01
10	SEAL	PP PLASTIC	01
09	SIPHON TUBE	ALUMINUM / PVC	01
08	"O" RING	NITRILE RUBBER	01
07	SAFETY PIN HOLDER	RUBBER / SOFT PVC	01
06	SAFETY PIN	MS CHROME PLATED	01
05	LEAVER LOCK	PP PLASTIC	01
04	PRESSURE GAUGE / INDICATOR	AS PER IS 15683:2018	01
03	VALVE	BRASS - M30 X 1.5 MALE THREADED	01
02	NECK RING	MS PIPE - M30 X 1.5 FEMALE THREADED	01
01	BODY	MILD STEEL SHEET OF 1.5 MM THICKNESS	01

					DATE	NAME
				DRAWN	22.12.22	VIJAY
				CHECK	22.12.22	SHEKHAR
				APP	22.12.22	AM
SYMBOL	REVISION DECRIPTION	DATE	BY			

TITLE :
CLEAN AGENT (FK-5-1-12) (STORED PRESSURE)
MS BODY 4 KG FIRE EXTINGUISHER

GAD NO. : INTIME-CLEAN AGENT-4-SP-MS

SCALE : NTS | SHEET : 1 OF 1

INTIME FIRE APPLIANCES PVT LTD
R.O. : 21/A, Ghanshyam Industrial Estate, Veera Desai Road, Andheri (W), Mumbai - 400053. Telephone : +91 22 2673 1826/ 2673 1852/ 4601 4302
WORKS: D-24/6, TTC Industrial Area, MIDC, Turbhe, Navi Mumbai - 400705. Telefax: 27634433 / 64512311 / 64523611.