
TECHNICAL DATA SHEET OF
THREE WAY INLET BREACHING




Fire Brigade Inlet Three Way Inlet Breaching	
Reference Standard	IS : 904
Inlet	Four Male Instantaneous Inlet of 63 mm With Built in Non returnable Valve
Outlet	Flanged 100mm
Material of Construc-Θon For Body	CI TO IS 210
Material of Construc- Θon For Non returnable Valve	GM As per IS 318 LTB-II

Industrial Estate, Veera Desai Road, Andheri (W), Mumbai - 400053. Telephone : +91 22 2673 1828/ 2673 1852/ 4601 4392
WORKS: D-24/6, TTC Industrial Area, MIDC, Turbhe, Navi Mumbai - 400705. Telefax: 27634433 / 64512311/64523611.
Email : orders@intimefire.com, ho@intimefire.com **: Website:** www.intimefire.com

THREE WAY INLET BREACHING



TOP VIEW



SECTION A-A
FRONT VIEW

SIDE VIEW

SR. NO.	DESCRIPTION
1	BODY
2	FLAT WASHER
3	MALE PARTS FOR (N.R.V. -63MM)
4	SEAT VALVE
5	SEAT WASHER
6	WASHER
7	NUT
8	SPRING
9	LOCK NUT FOR SPRING
10	BLANK CAP
11	CHAIN
12	DRAIN VALVE
13	

FLANGE DIMENSIONS**				
STD./TABLE	FALANGE Ø	P.C.D	NO. OF HOLES	HOLE Ø
IS 1538	220	180	8	19
AS PER CUSTOMER REQUIREMENT	**	**	**	**

Note: 1) All Dimensions are in mm if not specified.
2) Tolerance where not specified shall be ±0.5 mm.

TECHNICAL DATA SHEET OF
THREE WAY INLET BREACHING

TECHNICAL DATASHEET FOR THREE WAY INLET BREACHING	
DATASHEET NO. :	INTIME-TDS-10
CODE/STANDARD	IS 904
SIZE	63mm
INLET	Three Male Instantenous Inlet of 63 mm With Built in N.R.V
OUTLET	100 mm NB Flanged Outlet
MATERIAL OF CONSTRUCTION	
Body	CI to IS:210
N.R.V. Male, Seat Valve	GM to IS:318 Gr. LTB II
Spring	IS:7608
Rubber Washer	Rubber to IS:937
Blank Cap	ABS Plastic
INSPECTION & TESTING	
Hydro Pressure Test	21 Kgf/cm2
MARKING	
Size	63mm
Year	Year of Manufacture

Industrial Estate, Veera Desai Road, Andheri (W), Mumbai - 400053. Telephone : +91 22 2673 1828/ 2673 1852/ 4601 4392
WORKS: D-24/6, TTC Industrial Area, MIDC, Turbhe, Navi Mumbai - 400705. Telefax: 27634433 / 64512311/64523611.
Email : orders@intimefire.com, ho@intimefire.com **: Website:** www.intimefire.com