INTIME FIRE APPLIANCES PVT. LTD.
safe with intime
AN ISO 9001:2015 Certified Company

Document No.: INTM-2025-STP-FFX-TM
Date Last Updated: 30/05/2025

TECHNICAL DATA SHEET


Product Name	**TROLLEY-MOUNTED FFX® LITHIUM-ION FIRE EXTINGUISHER** (Stored Pressure)		
Model Number	**STP-FFX-TM-25**	**STP-FFX-TM-50**	**STP-FFX-TM-75**
Description	25 Kg/50 Kg/75 Kg FFX Lithium Ion Extinguisher, MS Sheet body, brass forged valve, epoxy coated..		



DIMENSIONS			
Diameter (±10)	300 mm	400 mm	
Height (±10)	770 mm	950 mm	1200 mm
Filler Opening	45 mm		
Sheet Thickness	3 mm		
Full Weight (Approx)	74 Kg	110 Kg	130 Kg
ANTI-CORROSIVE TREATMENT			
Treatment	Phosphate treatment & epoxy powder coating (DFT ≥50 Micron)		
MISCELLANEOUS			
Inspection & Testing	As per approved QAP		
Approvals	PED		
Marking	As per IS 16018:2012		
Finish	PO Red (IS:5 (Shade 536/538)		
Refill & Care	IS 2190		
Packing	Corrugated paper & suitable jute bags		

GENERAL INFORMATION			
Type	Trolley Mounted, Stored Pressure		
Capacity	25 L	50 L	75 L
Fire Rating	20A:233B		
Certification	CE		
MATERIAL OF CONSTRUCTION			
Ext. Medium	FFX® Lion Fluorine Free Solution		
Propellant	Nitrogen		
Body	Mild Steel Sheet (IS:2062)		
Neck Ring	MS Pipe (IS:1239 (part-1))		
Valve	Brass (IS:319)		
Siphon Tube (Inlet/ Outlet)	MS pipe (IS:3601/IS:1239)		
Discharge Hose	PVC braided hose (Burst pressure ≥55 bar)		
Discharge Hose with Nozzle	PVC		
Trolley	Yes		
Trolley Wheel	Solid rubber / HDPE		
Carrying Handle	MS pipe		
PERFORMANCE DATA			
Eff. Discharge Time	≥30 Sec		
Discharge Range	≥6 m		
% of Discharge	≥85%		
Temperature Range	+5° C to 55° C		
WP (Max)	15 bar		
Service P. (Max)	18 bar		
ROUTINE TESTS			
Hydro Pressure (Pt)	35 bar (3.5 MPa) for 60 Sec		
Burst Pressure (Pb)	55 bar (5.5 MPa) for 60 Sec		
Type Tests	As per IS 16018:2012		

DESIGN DATA



1. Cylinder
2. Neck Ring
3. Valve
4. Pressure Gauge/Indicator
5. Siphon Tube
6. Discharge Hose
7. Discharge Nozzle
8. Carrying Handle
9. Trolley Wheel

DISCLAIMER: The images, drawings, and data in this data sheet are for reference purposes only and may change without notice. Intime Fire Appliances Pvt. Ltd. is not responsible for their use or accuracy unless explicitly stated. All trademarks, service marks, logos, images, and CAD drawings in this document belong to their respective owners, and unauthorized use is strictly prohibited.
MANUFACTURED IN INDIA BY INTIME FIRE APPLIANCES PVT. LTD. © 1998–2025. ALL RIGHTS RESERVED.

21 A, Ghanshyam Industrial Estate, Off Veera Desai Road, Andheri West, Mumbai, Maharashtra, INDIA - 400 053
D/24/6, TTC Industrial Area, MIDC Turbhe, Navi Mumbai, Maharashtra, INDIA - 400 705
SafeWithIntime
+91 22 4601 4392 | +91 22 4016 5950 | ho@intimefire.com | www.intimefire.com